

## Drinking Water Quality and Compliance Annual Notice to Consumers

### Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the Town of Whitewood water quality and sample submission compliance record for Jan 1, 2014 to December 31, 2014 This report was completed on April 16, 2015. Readers should refer to Water Security Agency's [Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202](#) for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: [http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html).

### Water Quality Standards Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform and Background Bacteria	0 Organisms/100 mL Less than 200/100 mL	52	52	0
		52	52	0

### Water Disinfection –

#### Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.22-0.88	0.15-0.76	52	52	100%

### Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests Required	# Tests Performed
Turbidity	<1.0	0.05-0.17	0	.17	365	365

### Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium and uranium.

The last sample for Chemical Health analysis was submitted on Dec. 27, 2012. Sample results indicated that the provincial drinking water quality standards were not exceeded. (or) Samples exceeded provincial water quality standards for the following parameters:

Parameter	Limit MAC (mg/L)	Limit IMAC (mg/L)	Sample Result(s)	# Samples Exceeding Limit	
Arsenic	<10		2.1µg/L	_____	* Results expressed as average values for communities or waterworks that fluoridate drinking water supplies or those with elevated concentrations of fluoride or nitrates.
Barium	1.0		<2.31µg/L	_____	
Boron		5.0	0.1µg/L	_____	
Cadmium	0.005		<0.56µg/L	_____	
Chromium	0.05		<0.11µg/L	_____	
Fluoride (avg*)	1.5		<0.05 mg/L	_____	
Lead	0.01		0.10µg/L	_____	
Nitrate (avg.*)	45.0		<0.2mg/L	_____	
Selenium	0.01		<0.96µg/L	_____	
Uranium	0.02		0.10µg/L	_____	



**Saskatchewan  
Ministry of  
Environment**



### Chemical- Trihalomethanes (THMs)

Parameter	THMs Limit (mg/L)	Sample Result Average	#Samples Required	#Samples Submitted
-----------	----------------------	--------------------------	----------------------	-----------------------

*Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMs. Waterworks using groundwater sources beyond the influence of surface water do not need to report THMs since sampling/analysis will not likely have been performed.*

### General Chemical

Parameter	Aesthetic Objectives* (mg/L)	Sample Results (average) mg/L	#Samples Required	#Samples Submitted
Alkalinity	500	85.8 mg/L		
Bicarbonate	No objective	101		
Calcium	No objective	3		
Carbonate	No Objective	0		
Chloride	250	1.3		
Conductivity	No objective	164µS/cm		
Hardness	800	12		
Magnesium	200	<0.01 mg/L		
PH	No objective	7.8 pH Units		
Sodium	300	36		
Sulphate	500	<0.9		
Total dissolved Solids	1500	148 mg/L		

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years is a ground water source and once per three months every second year if a surface water or blended surface/ground source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO<sub>3</sub>), magnesium, sodium, sulphate and total dissolved solids.

The last sample for General Chemical analysis was required in **2015** and submitted on **Jan. 5/15**. Sample results indicated that there were no exceedances of the provincial aesthetic objectives for the General Chemical category.

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality of water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazard. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

**More information on water quality and sample submission performance may be obtained from [www.saskh20.ca](http://www.saskh20.ca) or**

Town of Whitewood  
Box 129  
Whitewood, Sask.  
S0G 5C0  
735-2210  
735-2262 (fax)



**Saskatchewan  
Ministry of  
Environment**

